

## BRICKLAYERS

<p><b>GENERAL</b>                  - s299-303, &amp; 316-317                  Work Health and Safety                  Regulation 2011</p>	<ul style="list-style-type: none"> <li>• Work method statements available</li> <li>• Workers have construction Induction training card</li> </ul>
<p><b>WORK AT HEIGHTS</b>                  - S78-80; s306A-306O                  Work Health and Safety                  Regulation 2011                  - Scaffolding Code of Practice                  2009</p>	<ul style="list-style-type: none"> <li>• Controls in place if risk of fall <math>\geq</math> 2m e.g. edge protection, catch platform</li> <li>• Under 2m: A risk assessment must be done ie: hazards identified, risk assessed, and control measures implemented (e.g: if someone can fall onto something that will injure them- control the risk)</li> <li>• Adequate work platforms provided and used e.g. 5 planks</li> <li>• No gaps in perimeter protection</li> <li>• Penetrations covered/secured</li> </ul>
<p><b>TOOLS/ EQUIPMENT</b>                  - S204-213; S214 &amp; 215                  Work Health and Safety                  Regulation 2011</p>	<ul style="list-style-type: none"> <li>• Maintained in good condition</li> <li>• Used only for intended purpose</li> <li>• Guards in place when used</li> </ul>
<p><b>FALLING OBJECTS</b>                  - S54-55 &amp; s315B – 315M                  Work Health and Safety                  Regulation 2011</p>	<ul style="list-style-type: none"> <li>• Workers not throwing up tools and materials</li> <li>• Brick guards/mesh in place in scaffold</li> <li>• Exclusion zone and/or catch platform</li> <li>• Controls implemented for loads being lifted over adjoining areas e.g. adjoining area closed/gantry erected</li> </ul>
<p><b>ELECTRICAL</b>                  - s90 Electrical Safety Regulation                  2002</p>	<ul style="list-style-type: none"> <li>• Electrical equipment kept away from water</li> <li>• Earth Leakage Switch installed on mains supply</li> <li>• Extension leads secured and protected from damage</li> <li>• Testing and tagging current</li> </ul>
<p><b>ACCESS HOUSEKEEPING</b>                  - s314(a) &amp; 315 Work Health and                  Safety Regulation 2011</p>	<ul style="list-style-type: none"> <li>• Working area kept clear/tidy</li> <li>• Trip hazards managed e.g. material neatly stacked</li> <li>• Excess mortar appropriately disposed e.g. designated areas</li> </ul>
<p><b>MANUAL TASKS</b>                  - S60-61 Work Health and Safety                  Regulation 2011</p>	<ul style="list-style-type: none"> <li>• Working platforms adjusted for different working heights i.e. no excessive bending or work above head and shoulder height</li> <li>• High risk manual tasks identified e.g. continuous heavy lifting, excessive pulling/pushing movements</li> <li>• Controls implemented for high risk manual tasks e.g. use trolleys to lift bricks from pallet, not pushing/pulling loaded pallet trucks onto or off hoist platform</li> </ul>

<p><b>NOISE</b> - s56-59 Work Health and Safety Regulation 2011 &amp; - Managing Noise and Preventing Hearing Loss at Work C.O.P</p>	<ul style="list-style-type: none"> <li>• Hearing protection worn when cutting bricks</li> <li>• Controls implemented to minimise exposure e.g. hearing protection, temporary sound absorption screens</li> </ul>
<p><b>HAZARDOUS CHEMICALS</b> - s341-346 &amp; s351-358 Work Health and Safety Regulation 2011 &amp; - Hazardous Chemicals Code of Practice 2003</p>	<ul style="list-style-type: none"> <li>• Safety Data Sheets (SDS) available for substances classified as hazardous (e.g. cement, lime, hydrochloric acid).</li> <li>• Hazardous chemicals safely and securely stored when not in use.</li> <li>• Workers trained in safe handling of hazardous chemicals (e.g. wear gloves when handling hydrochloric acid).</li> <li>• Hazardous chemicals labelled (includes safety and risk phrases).</li> <li>• Hazardous chemicals not stored in food and/or drink containers (e.g. hydrochloric acid not stored in drink bottles).</li> </ul>
<p><b>PERSONAL PROTECTIVE EQUIPMENT</b> - s44-47 Work Health and Safety Regulation 2011</p>	<ul style="list-style-type: none"> <li>• Workers wearing steel capped boots, hard hat with shade brim, shirts and sunglasses</li> </ul>
<p><b>AMENITIES</b> - s41; 42; 315A; Schedule 5A Work Health and Safety Regulation 2011</p>	<ul style="list-style-type: none"> <li>• Sheltered meal area provided</li> <li>• Workers have access to toilets (1 toilet for each 15 workers or part thereof)</li> <li>• Hand and face washing facilities provided (separate from toilets)</li> <li>• Workers have access to potable, clean and cool drinking water</li> <li>• First aid equipment provided is hygienic and appropriate for the size and complexity of the project</li> </ul>
<p><b>EMERGENCY PREPAREDNESS &amp; RESPONSE</b> - S43; Work Health and Safety Regulation 2011</p>	<ul style="list-style-type: none"> <li>• Fire extinguishers available and testing current</li> <li>• Emergency evacuation plan available</li> <li>• Workers briefed on emergency evacuation plan</li> </ul>

[www.qnt.cfmeu.org.au](http://www.qnt.cfmeu.org.au)  
ABN: 24 502 631 846